



Lassen County Environmental Health Division
1445 Paul Bunyan Road, Suite B, Susanville, CA 96130
TELEPHONE: (530) 251-8528 FAX: (530) 251-2668

SWIMMING POOL INSPECTION REPORT

DBA/NAME <i>Comfort Inn & Suites</i>		CITY <i>Susanville</i>		DATE <i>6/1/23</i>				
ADDRESS <i>3015 Riverside Drive</i>		RECHECK DATE						
OWNER/OPERATOR <i>Tripe E Investment Co., Inc.</i>		SERVICE		SPA TEMPERATURE <i>103</i> °F				
POOL TYPE / PR# <i>Pool 2</i>	DISINFECTANT RESIDUAL <i>Br</i> ppm	COMBINED CHLORINE RESIDUAL <i>7.2</i> ppm	pH <i>7.2</i>	CYANURIC ACID <i>4.0</i> ppm	FLOW RATE <i>4.0</i> gpm	INFLUENT GAUGE <i>psi</i>	EFFLUENT GAUGE <i>psi</i>	VACUUM GAUGE <i>psi</i>
POOL TYPE / PR# <i>Spa 1</i>	DISINFECTANT RESIDUAL <i>Br</i> ppm	COMBINED CHLORINE RESIDUAL <i>7.2</i> ppm	pH <i>7.2</i>	CYANURIC ACID <i>4.0</i> ppm	FLOW RATE <i>4.0</i> gpm	INFLUENT GAUGE <i>psi</i>	EFFLUENT GAUGE <i>psi</i>	VACUUM GAUGE <i>psi</i>
POOL TYPE / PR#	DISINFECTANT RESIDUAL <i>Br</i> ppm	COMBINED CHLORINE RESIDUAL <i>7.2</i> ppm	pH <i>7.2</i>	CYANURIC ACID <i>4.0</i> ppm	FLOW RATE <i>4.0</i> gpm	INFLUENT GAUGE <i>psi</i>	EFFLUENT GAUGE <i>psi</i>	VACUUM GAUGE <i>psi</i>
The checked items represent violations and must be corrected as follows:								
WATER CHEMISTRY <i>Br Hcn 2.0 ppm (pool) 4.0 ppm (spa)</i>								
Maintain a free chlorine residual between 1.0 ppm and 10.0 ppm, or 2.0 and 10.0 ppm if cyanuric acid is used, in swimming pools.								
Maintain a free chlorine residual between 3.0 and 10.0 ppm in spas, wading pools and spray grounds at all times. <i>4.0 Br</i>								
Maintain the level of combined chlorine between 0.4 ppm at all times.								
Maintain a pH between 7.2 and 7.8.								
Maintain the level of cyanuric acid below 100 ppm.								
EQUIPMENT								
Backwash the filter(s).								
Provide, repair, or replace the vacuum gauge and/or influent/effluent pressure gauge(s).								
Provide, repair, or replace the flowmeter.								
Maintain disinfectant to the automatic feeder.								
Operate the recirculation system, including the disinfectant feeder, at all times the facility is open for use or longer as necessary to maintain the water clean and clear.								
RESTROOMS								
Showers and lavatories shall be provided with hot (max. 110 degrees Fahrenheit) and cold running water.								
Provide soap in permanently installed soap dispensers, sanitary towels or hot air blowers, and toilet tissues at toilet facilities.								
MAINTENANCE AND SUPERVISION								
Provide / maintain a self-closing gate / door to pool area with self-latching hardware at least 42 inches above finished grade.								
Maintain skimmer in good working order; weir assembly, strainer basket and diverter valve assembly are required.								
Limit spa pool water temperature to a maximum of 104 degrees Fahrenheit.								
Replace broken / missing / unreadable depth marker tiles and / or pool tiles.								
Secure / replace drain cover with an approved type which can only be removed with tools. Main drain must be clearly visible at all times.								
Provide / repair / replace the safety vacuum release system (SVRS).								
Secure / repair / replace loose stair handrail(s) / ladder / ladder step treads / grab rails.								
Maintain a daily log of the pool operation, disinfectant residual, combined chlorine, pH and maintenance procedures.								
Provide an approved DPD test kit.								
Provide keys to this department to gates / doors / equipment room(s) / and / or restroom facilities for inspection.								
SAFETY EQUIPMENT AND SIGNS – SEE REVERSE FOR SAFETY EQUIPMENT AND SIGN REQUIREMENTS								
All safety equipment must be readily accessible to pool users. All required signs must be clearly visible from the pool deck.								
SAFETY EQUIPMENT: ☐ Rescue Pole ☐ Life Ring								
SIGNS: ☐ Artificial Respiration and CPR ☐ Emergency Phone Numbers ☐ Occupant Capacity P/S ☐ No Lifeguard on duty								
☐ Spa Caution ☐ Emergency Shut-Off Switch ☐ Keep Closed ☐ No Diving Allowed								
☐ Emergency Exit ☐ Diarrhea								

☐ Pursuant to California Code of regulations, Section 65545, THIS POOL/SPA IS OFFICIALLY CLOSED. This pool shall not be placed in operation until all violations have been corrected and upon specific written approval by this Division. Call to schedule a reinspection. DO NOT REMOVE THE CLOSED SIGN.

Environmental Health Specialist: *[Signature]* Phone: *(530) 251-8528* Page *1* of *1* Received by: *[Signature]*
Once Spa reaches 4.0 ppm Br may open DISTRIBUTION: White – Office *[Signature]* – Owner's Copy